



EMSL Analytical, Inc.

10752 Baltimore Avenue Beltsville, MD 20705

Tel/Fax: (301) 937-5700 / (301) 937-5701

<http://www.EMSL.com> / beltsvillelab@emsl.com

EMSL Order: 192204794

Customer ID: YNNA50

Customer PO:

Project ID: Montgomery County Public Sch

Attention: John Ndanga
Ynn & Associates, Inc.
4808 Continental Drive
Olney, MD 20832

Phone: (301) 260-0687

Fax:

Received Date: 06/26/2022 15:15 PM

Analysis Date: 06/26/2022

Collected Date: 06/25/2022

Project: Poolesville High School (Montgomery County Public Schools- MCPS)

Test Report: Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Appendix A to Subpart E

Sample	Location	Volume (Liters)	Area Analyzed (mm ²)	Non Asb	Asbestos Type(s)	#Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration	
						≥0.5μ < 5μ	≥5μ		(S/mm ²)	(S/cc)
062522-T1 192204794-0001	Room 48	1200.00	0.0650	0	None Detected	0	0	0.0049	<15.00	<0.0049
062522-T2 192204794-0002	Room 48	1200.00	0.0650	0	None Detected	0	0	0.0049	<15.00	<0.0049
062522-T3 192204794-0003	Room 48	1200.00	0.0650	0	None Detected	0	0	0.0049	<15.00	<0.0049
062522-T4 192204794-0004	Room 48	1200.00	0.0650	0	None Detected	0	0	0.0049	<15.00	<0.0049
062522-T5 192204794-0005	Room 48	1200.00	0.0650	0	None Detected	0	0	0.0049	<15.00	<0.0049

Analyst(s)

George Malone (5)

Joe Centifonti, Laboratory Manager
or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. This report must not be used to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. Results reported in structures/cm3 are not covered by the laboratory's NVLAP accreditation. Measurement of uncertainty available upon request.

Samples analyzed by EMSL Analytical, Inc. Beltsville, MD NVLAP Lab Code 200293-0

Initial report from: 06/26/2022 17:29 PM