



MCPS RADON TESTING - EXECUTIVE SUMMARY

Site Name	Brookhaven Elementary School
Date of Report	2/3/2020
Round of Testing	Initial Follow-up Post Remediation 2 year testing 5 year testing HVAC Upgrade Window Replacement New Addition New Facility
# of Rooms Tested	42
# Rooms \geq 4.0 pCi/L	0
Lowest Value	<0.3 pCi/L
Highest Value	1.1 pCi/L

Project Status

Current Project Status at this time: Testing Complete; no further action.



2/3/2020

Mr. Richard Cox, MS
Environmental Team Leader
Montgomery County Public Schools
Division of Maintenance
Gaithersburg, Maryland 20879

Re: Radon Testing Services

KCI Job #12146341126

Location: Brookhaven Elementary School

4610 Renn Street
Rockville, Maryland 20853

Dear Mr. Cox:

KCI Technologies, Inc. (KCI) is pleased to submit the following report to Montgomery County Public Schools pursuant to completing a “short-term” 3-day radon test for the Brookhaven Elementary School, located at 4610 Renn Street in Rockville, Maryland 20853 (subject site).

SCOPE OF SERVICES

KCI conducted radon testing at the subject site to evaluate indoor radon levels relative to the USEPA's recommended action level of 4.0 picocuries per Liter (pCi/L) - the level at which EPA recommends that schools take action to reduce the level. KCI conducted the radon testing in accordance with American Association of Radon Scientists and Technologists (AARST) *Protocol for Conducting Measurements of Radon and Radon Decay Products in Schools and Large Buildings*. A National Radon Proficiency Program (NRPP) Radon Measurement Provider (certification #111004 RT) supervised the testing. Additional information on radon management and the health effects of radon exposure is available from <https://www.montgomeryschoolsmd.org/departments/facilities/maintenance/default.aspx?id=458858> or www.epa.gov/radon.

KCI visited the site on 12/16/2019 and deployed 54 activated charcoal (AC) radon test kits. KCI deployed radon test kits in frequently-occupied ground contact rooms, and other areas, (if applicable) in accordance with AARST guidance.

A floor plan map of the building with the test locations is included as Appendix A of this report.

As a quality control measure, KCI included duplicate samples, field blanks, lab transit blanks, and office blanks in accordance with AARST recommendations. In addition, KCI submitted sixty (60) test kits to Bowser-Morner, Inc. as spike samples. The spiked tests were exposed to a known radon concentration by Bowser-Morner, Inc. prior to being returned to the laboratory for analysis.

KCI returned to the site on 12/19/2019 to retrieve the radon sampling test kits. KCI shipped all radon tests via overnight delivery to Aircheck, Inc. for analysis by gamma-ray spectroscopy. Aircheck, Inc. is a National Radon Safety Board (NRSB) radon measurement provider and is a certified analytical laboratory for radon analysis (certification #ARL1402) located at 1936 Butler Bridge Road, Mills River, North Carolina.

EVALUATION OF TESTING CONDITIONS

These tests represent:

- Follow-up to initial testing.

These tests were conducted to:

- Evaluate radon concentrations at the facility.

According to AARST, *Protocol for Conducting Measurements of Radon and Radon Decay Products in Schools and Large Buildings*, ideal testing conditions would be when the building is fully occupied and the heating system is active. For this test, the facility's HVAC system was operating in heating mode; therefore, KCI concludes that this test was conducted during ideal testing conditions.

KCI recorded observations of the following conditions in each room at the time of deployment and collection of the radon test kits:

- Indoor temperature,
- HVAC Operation,
- Dehumidifier operation,
- Humidifier operation,
- Ceiling fan operation, and
- Open windows or doors.

KCI also compiled weather data for the testing period and conducted observations of relevant field conditions. During the test period, weather records indicate low temperatures were in the lower-20s and high temperatures were in the lower-40s. Maximum sustained winds ranged from 12-26 miles per hour. Average humidity was around 67%. 0.54 inches of precipitation (rain and snow) was recorded during the testing period.

RESULTS

The sampling locations and analytical results are listed on Table 1 (Attachment B). The quality control sample locations and analytical results are listed on Table 2 (Attachment B). Sampling locations and associated test kit identification numbers and relevant field observations are listed on Table 3 (Attachment B). The laboratory analytical results are included in Attachment C. Laboratory results and exposure data for the spike samples are also included in Attachment C.

The results of the radon test analysis indicated the following:

Radon Concentration	Room	Result
≥4.0 pCi/L	None	N/A
≤4.0 pCi/L	See Attachment B	See Attachment B

Quality Control Samples	
Results of Blank Canisters:	The office blanks, and lab transit blanks had test results of less than the laboratory detection limit of 0.3 pCi/L.
Adequate Laboratory Precision?	Review of the duplicate sample analysis indicates that adequate laboratory measurement precision was achieved.
Spike Sample Analysis:	The Spike sample analysis results indicate the laboratory is operating within statistical control limits.

Our professional services have been performed in accordance with customary principles and practices in the field of industrial hygiene and engineering. If you have any questions or comments regarding this report, please feel free to contact me at 410-316-7800.

Sincerely,

Mr. Tyler P. McCleaf
Radon Measurement Provider
111004 RT

KCI Technologies, Inc.

Attachments:

A- Floor Plan with Test Locations

B - Tables 1-3, Radon Test Summary Spreadsheets

C- Laboratory Analytical Results

ATTACHMENT A

Floor Plan With Test Locations

ATTACHMENT B

Radon Test Summary Spreadsheet

Table Notes:

AC- Activated Charcoal

ACI- Air Chek, Inc.

D- Duplicate

FB- Field Blank

KCI- KCI Technologies, Inc.

OB- Office Blank

PM- Project Manager

QC- Quality Control

Table 1- Radon Testing Results		
Brookhaven Elementary School		
Test Period: 12/16/2019-12/19/2019		
Kit Number	Room / Area	Result
9340501	109	< 0.3
9340502	108	0.5
9340503	105	< 0.3
9340504	103	0.7
9340505	101	0.7
9340506	101	< 0.3
9340507	118	0.6
9340508	118	< 0.3
9340509	122	< 0.3
9340510	127	0.5
9340511	131	0.6
9340512	MEDIA OFFICE	0.7
9340513	MEDIA	0.5
9340514	AP ROOM	< 0.3
9340515	AP ROOM	< 0.3
9340516	AP ROOM	< 0.3
9340517	MAIN OFFICE	0.5
9340518	PRINCIPAL	< 0.3
9340519	WORK ROOM	0.6
9340520	HEALTH	< 0.3
9340521	CONFERENCE	< 0.3
9340522	226	< 0.3
9340523	236	< 0.3
9340524	231	< 0.3
9340525	231	< 0.3
9340526	209	< 0.3
9340527	209	< 0.3
9341674	161	< 0.3
9341675	162	0.9
9341676	162	< 0.3
9341677	163	< 0.3
9341678	166	0.5
9341679	164	0.8
9341680	164	1
9341681	136	0.7
9341682	138	1
9341683	139	0.9
9341684	137	1
9341685	137A	< 0.3
9341686	137A	0.9
9341687	135	1.1
9341688	135	< 0.3
9341689	134	0.6
9341690	132	0.6
9341691	133	0.8
9341692	133A	0.7
9341693	130	0.6
9341694	131	1
9341695	112	< 0.3
9341696	112	0.7

9341697	113	< 0.3
9341698	114	< 0.3
9341699	111	< 0.3
9341700	110	< 0.3
9341376	OFFICE BLANK	< 0.3

Table 2- Radon Testing Results			
Brookhaven Elementary School			
Test Period: 12/16/2019-12/19/2019			
Kit Number	QC Type	Room / Area	Result
9341676	D	162	<0.3
9341686	D	137A	0.9
9341688	FB	135	<0.3
9341696	D	112	0.7
9340506	D	101	<0.3
9340508	FB	118	<0.3
9340516	D	AP ROOM	<0.3
9340525	FB	231	<0.3
9340526	D	209	<0.3
9341377	TRANSIT BLANK	NA	0.5
9341379	TRANSIT BLANK	NA	< 0.3
9341380	TRANSIT BLANK	NA	< 0.3
9341398	TRANSIT BLANK	NA	< 0.3

ATTACHMENT C

Laboratory Analytical Results

Radon test result report for:
BROOKHAVEN ES
MAIN

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9340505	101	2019-12-16 @ 1:00 pm	2019-12-19 @ 11:00 am	0.7 ± 0.4	2019-12-23
9340506	101	2019-12-16 @ 1:00 pm	2019-12-19 @ 11:00 am	< 0.3	2019-12-23
9340504	103	2019-12-16 @ 1:00 pm	2019-12-19 @ 11:00 am	0.7 ± 0.4	2019-12-23
9340503	105	2019-12-16 @ 1:00 pm	2019-12-19 @ 11:00 am	< 0.3	2019-12-23
9340502	108	2019-12-16 @ 1:00 pm	2019-12-19 @ 11:00 am	0.5 ± 0.4	2019-12-23
9340501	109	2019-12-16 @ 1:00 pm	2019-12-19 @ 11:00 am	< 0.3	2019-12-23
9341700	110	2019-12-16 @ 1:00 pm	2019-12-19 @ 11:00 am	< 0.3	2019-12-23
9341699	111	2019-12-16 @ 1:00 pm	2019-12-19 @ 11:00 am	< 0.3	2019-12-23
9341695	112	2019-12-16 @ 1:00 pm	2019-12-19 @ 11:00 am	< 0.3	2019-12-23
9341696	112	2019-12-16 @ 1:00 pm	2019-12-19 @ 11:00 am	0.7 ± 0.4	2019-12-23
9341697	113	2019-12-16 @ 1:00 pm	2019-12-19 @ 11:00 am	< 0.3	2019-12-23
9341698	114	2019-12-16 @ 1:00 pm	2019-12-19 @ 11:00 am	< 0.3	2019-12-23
9340507	118	2019-12-16 @ 1:00 pm	2019-12-19 @ 11:00 am	0.6 ± 0.4	2019-12-23
9340508	118	2019-12-16 @ 1:00 pm	2019-12-19 @ 11:00 am	< 0.3	2019-12-23
9340509	122	2019-12-16 @ 2:00 pm	2019-12-19 @ 11:00 am	< 0.3	2019-12-23
9340510	127	2019-12-16 @ 2:00 pm	2019-12-19 @ 11:00 am	0.5 ± 0.4	2019-12-23
9341693	130	2019-12-16 @ 1:00 pm	2019-12-19 @ 11:00 am	0.6 ± 0.3	2019-12-23
9340511	131	2019-12-16 @ 2:00 pm	2019-12-19 @ 11:00 am	0.6 ± 0.4	2019-12-23
9341694	131	2019-12-16 @ 1:00 pm	2019-12-19 @ 11:00 am	1.0 ± 0.4	2019-12-23
9341690	132	2019-12-16 @ 1:00 pm	2019-12-19 @ 11:00 am	0.6 ± 0.3	2019-12-23
9341691	133	2019-12-16 @ 1:00 pm	2019-12-19 @ 10:00 am	0.8 ± 0.3	2019-12-23
9341692	133A	2019-12-16 @ 1:00 pm	2019-12-19 @ 10:00 am	0.7 ± 0.4	2019-12-23
9341689	134	2019-12-16 @ 1:00 pm	2019-12-19 @ 11:00 am	0.6 ± 0.4	2019-12-23
9341688	135	2019-12-16 @ 1:00 pm	2019-12-19 @ 10:00 am	< 0.3	2019-12-23
9341687	135	2019-12-16 @ 1:00 pm	2019-12-19 @ 10:00 am	1.1 ± 0.4	2019-12-23
9341681	136	2019-12-16 @ 12:00 pm	2019-12-19 @ 10:00 am	0.7 ± 0.3	2019-12-23
9341684	137	2019-12-16 @ 1:00 pm	2019-12-19 @ 10:00 am	1.0 ± 0.4	2019-12-23
9341685	137A	2019-12-16 @ 1:00 pm	2019-12-19 @ 10:00 am	< 0.3	2019-12-23
9341686	137A	2019-12-16 @ 1:00 pm	2019-12-19 @ 10:00 am	0.9 ± 0.4	2019-12-23
9341682	138	2019-12-16 @ 12:00 pm	2019-12-19 @ 10:00 am	1.0 ± 0.4	2019-12-23
9341683	139	2019-12-16 @ 1:00 pm	2019-12-19 @ 10:00 am	0.9 ± 0.4	2019-12-23
9341674	161	2019-12-16 @ 12:00 pm	2019-12-19 @ 10:00 am	< 0.3	2019-12-23
9341675	162	2019-12-16 @ 12:00 pm	2019-12-19 @ 10:00 am	0.9 ± 0.4	2019-12-23
9341676	162	2019-12-16 @ 12:00 pm	2019-12-19 @ 10:00 am	< 0.3	2019-12-23
9341677	163	2019-12-16 @ 12:00 pm	2019-12-19 @ 10:00 am	< 0.3	2019-12-23
9341680	164	2019-12-16 @ 12:00 pm	2019-12-19 @ 10:00 am	1.0 ± 0.3	2019-12-23
9341679	164	2019-12-16 @ 12:00 pm	2019-12-19 @ 10:00 am	0.8 ± 0.3	2019-12-23

Radon test result report for:
BROOKHAVEN ES
MAIN

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9341678	166	2019-12-16 @ 12:00 pm	2019-12-19 @ 10:00 am	0.5 ± 0.3	2019-12-23
9340527	209	2019-12-16 @ 2:00 pm	2019-12-19 @ 11:00 am	< 0.3	2019-12-23
9340526	209	2019-12-16 @ 2:00 pm	2019-12-19 @ 11:00 am	< 0.3	2019-12-23
9340522	226	2019-12-16 @ 2:00 pm	2019-12-19 @ 11:00 am	< 0.3	2019-12-23
9340524	231	2019-12-16 @ 2:00 pm	2019-12-19 @ 11:00 am	< 0.3	2019-12-23
9340525	231	2019-12-16 @ 2:00 pm	2019-12-19 @ 11:00 am	< 0.3	2019-12-23
9340523	236	2019-12-16 @ 2:00 pm	2019-12-19 @ 11:00 am	< 0.3	2019-12-23
9340515	AP ROOM	2019-12-16 @ 2:00 pm	2019-12-19 @ 11:00 am	< 0.3	2019-12-23
9340516	AP ROOM	2019-12-16 @ 2:00 pm	2019-12-19 @ 11:00 am	< 0.3	2019-12-23
9340514	AP ROOM	2019-12-16 @ 2:00 pm	2019-12-19 @ 11:00 am	< 0.3	2019-12-23
9340521	CONFERENCE	2019-12-16 @ 2:00 pm	2019-12-19 @ 12:00 pm	< 0.3	2019-12-23
9340520	HEALTH	2019-12-16 @ 2:00 pm	2019-12-19 @ 11:00 am	< 0.3	2019-12-23
9340517	MAIN OFFICE	2019-12-16 @ 2:00 pm	2019-12-19 @ 11:00 am	0.5 ± 0.4	2019-12-23
9340513	MEDIA	2019-12-16 @ 2:00 pm	2019-12-19 @ 11:00 am	0.5 ± 0.4	2019-12-23
9340512	MEDIA OFFICE	2019-12-16 @ 2:00 pm	2019-12-19 @ 11:00 am	0.7 ± 0.4	2019-12-23
9340518	PRINCIPAL	2019-12-16 @ 2:00 pm	2019-12-19 @ 11:00 am	< 0.3	2019-12-23
9340519	WORK ROOM	2019-12-16 @ 2:00 pm	2019-12-19 @ 11:00 am	0.6 ± 0.4	2019-12-23

EXPOSURE IN BOWSER-MORNER RADON CHAMBER

CLIENT KCI Technologies Inc Job Number 193598

NOMINAL Conditions: Radon Conc _____ pCi/L Rel. Hum _____ % Temp. _____ F

Temp °F 70.1
RH % 50.1
Avg pCi/L 25.4

Date Start: 12/21/19 Date Stop: 12/23/19

Time Start: 0815 Time Stop: 0815

(Group 1)
Device No.'s: (20) Char. Bags-

9340001 thru 9340020

55

Temp °F 70.1
RH % 50.1
Avg pCi/L 25.4

Date Start: 12/21/19 Date Stop: 12/23/19

Time Start: 0829 Time Stop: 0820

(Group 2)
Device No.'s: (20) Char. Bags-

9340021 thru 9340040

54

Temp °F 70.1
RH % 50.1
Avg pCi/L 25.4

Date Start: 12/21/19 Date Stop: 12/23/19

Time Start: 0825 Time Stop: 0825

(Group 3)
Device No.'s: (20) Char. Bags-

9340041 thru 9340060

53

Note: All times are in 24-hour (military) notation, Eastern Standard Time (EST)
Background = 7 µR/h Elevation = 820 ft



Radon Test Kit Chain of Custody

Project Name: MCPS Radon 2019 Week 2

Name of Schools:

- | | |
|-------------------------------|---------------------|
| 1. Argyle M.S. | 13. Candelwood E.S. |
| 2. Banneker M.S. | 14. Drew E.S. |
| 3. Bel Pre E.S. | 15. Fallsmead E.S. |
| 4. Bells Mill E.S. | 16. Farquhar M.S. |
| 5. Bethesda Maintenance Depot | 17. Kennedy H.S. |
| 6. Beverly Farms E.S. | 18. Luxmanor E.S. |
| 7. Blake H.S. | 19. Magruder H.S. |
| 8. Dufief E.S. | 20. Redland M.S. |
| 9. Briggs Chaney M.S. | 21. Shriver E.S. |
| 10. Brookhaven E.S. | 22. Smith Center |
| 11. Burtonsville E.S. | 23. Viers Mill E.S. |
| 12. Cabin John M.S. | 24. Wheaton H.S. |

	Date	Initials
Radon Test Kits Deployed	12/16/19 to 12/17/19	
Radon Test Kits Collected	12/19/19 to 12/20/19	
Radon Test Kits Shipped to Lab*	12/20/19	
Radon Test Kits Received by Lab*	12/23/19	

*All samples sent to Air Check, Inc., 1936 Butler Bridge Rd, Mills River, NC 28759

Radon test result report for:

MCPS - Spike Sample Lab Results. Measured values are satisfactory, i.e., within $\pm 25\%$ of the chamber's reference value (25.7 pCi/L).

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9340067	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	25.1 \pm 2.4 D	2020-01-03
9340035	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	22.5 \pm 2.3 D	2020-01-03
9340003	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	25.2 \pm 2.4 D	2020-01-03
9340089	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	23.3 \pm 2.3 D	2020-01-03
9340072	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	18.3 \pm 2.0 D	2020-01-03
9340040	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	27.3 \pm 2.6 D	2020-01-03
9340008	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	24.8 \pm 2.5 D	2020-01-03
9340094	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	24.7 \pm 2.5 D	2020-01-03
9340099	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	27.5 \pm 2.6 D	2020-01-03
9340077	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	25.2 \pm 2.5 D	2020-01-03
9340045	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	24.7 \pm 2.4 D	2020-01-03
9340013	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	25.9 \pm 2.6 D	2020-01-03
9340018	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	29.1 \pm 2.8 D	2020-01-03
9341704	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	25.1 \pm 2.4 D	2020-01-03
9340050	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	27.2 \pm 2.6 D	2020-01-03
9340023	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	28.2 \pm 2.7 D	2020-01-03
9341709	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	25.5 \pm 2.4 D	2020-01-03
9340055	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	27.8 \pm 2.6 D	2020-01-03
9340060	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	27.3 \pm 2.5 D	2020-01-03
9340028	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	23.9 \pm 2.3 D	2020-01-03
9341714	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	28.3 \pm 2.7 D	2020-01-03
9340082	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	26.4 \pm 2.6 D	2020-01-03
9340065	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	24.2 \pm 2.4 D	2020-01-03
9340033	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	26.2 \pm 2.5 D	2020-01-03
9341719	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	26.7 \pm 2.5 D	2020-01-03
9340001	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	26.3 \pm 2.5 D	2020-01-03
9340087	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	24.8 \pm 2.4 D	2020-01-03
9340070	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	19.5 \pm 2.4 D	2020-01-03
9340038	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	24.7 \pm 2.3 D	2020-01-03
9340006	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	25.2 \pm 2.4 D	2020-01-03
9340092	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	31.4 \pm 2.8 D	2020-01-03
9340097	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	26.7 \pm 2.5 D	2020-01-03
9340075	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	29.6 \pm 2.6 D	2020-01-03
9340043	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	28.1 \pm 2.6 D	2020-01-03
9340011	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	26.8 \pm 2.5 D	2020-01-03
9340016	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	23.2 \pm 2.4 D	2020-01-03
9341702	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	26.8 \pm 2.5 D	2020-01-03

Radon test result report for:**S****N/A**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9340048	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	25.5 ± 2.4 D	2020-01-03
9340021	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	26.7 ± 2.6 D	2020-01-03
9341707	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	25.8 ± 2.4 D	2020-01-03
9340053	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	25.8 ± 2.5 D	2020-01-03
9340058	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	28.5 ± 2.7 D	2020-01-03
9340026	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	25.9 ± 2.4 D	2020-01-03
9341712	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	24.3 ± 2.4 D	2020-01-03
9340080	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	25.1 ± 2.4 D	2020-01-03
9340063	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	25.8 ± 2.5 D	2020-01-03
9340031	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	24.9 ± 2.4 D	2020-01-03
9341717	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	25.7 ± 2.4 D	2020-01-03
9340085	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	26.9 ± 2.5 D	2020-01-03
9340068	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	26.2 ± 2.5 D	2020-01-03
9340036	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	23.6 ± 2.3 D	2020-01-03
9340004	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	26.9 ± 2.6 D	2020-01-03
9340090	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	26.3 ± 2.5 D	2020-01-03
9340073	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	26.8 ± 2.5 D	2020-01-03
9340041	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	25.6 ± 2.4 D	2020-01-03
9340009	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	24.1 ± 2.4 D	2020-01-03
9340095	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	25.2 ± 2.5 D	2020-01-03
9340100	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	24.5 ± 2.4 D	2020-01-03
9340078	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	25.0 ± 2.4 D	2020-01-03
9340046	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	28.0 ± 2.6 D	2020-01-03
9340014	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	21.8 ± 2.8 D	2020-01-03
9340019	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	26.0 ± 2.5 D	2020-01-03
9341705	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	27.8 ± 2.6 D	2020-01-03
9340051	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	25.5 ± 2.4 D	2020-01-03
9340056	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	27.7 ± 2.6 D	2020-01-03
9340024	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	28.3 ± 2.5 D	2020-01-03
9341710	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	24.2 ± 2.3 D	2020-01-03
9340061	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	28.9 ± 2.6 D	2020-01-03
9340029	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	23.0 ± 2.3 D	2020-01-03
9341715	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	27.0 ± 2.5 D	2020-01-03
9340083	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	24.9 ± 2.4 D	2020-01-03
9340066	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	25.1 ± 2.4 D	2020-01-03
9340034	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	26.4 ± 2.5 D	2020-01-03
9341720	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	25.3 ± 2.5 D	2020-01-03

Radon test result report for:**S****N/A**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9340002	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	25.7 ± 2.5 D	2020-01-03
9340088	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	26.4 ± 2.5 D	2020-01-03
9340071	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	24.9 ± 2.4 D	2020-01-03
9340039	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	26.9 ± 2.5 D	2020-01-03
9340007	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	26.9 ± 2.4 D	2020-01-03
9340093	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	25.1 ± 2.5 D	2020-01-03
9340098	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	26.8 ± 2.5 D	2020-01-03
9340076	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	25.1 ± 2.5 D	2020-01-03
9340044	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	25.2 ± 2.5 D	2020-01-03
9340012	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	22.5 ± 2.2 D	2020-01-03
9340017	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	25.3 ± 2.5 D	2020-01-03
9341703	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	26.0 ± 2.5 D	2020-01-03
9340049	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	26.0 ± 2.5 D	2020-01-03
9340022	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	28.6 ± 2.6 D	2020-01-03
9341708	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	28.8 ± 2.8 D	2020-01-03
9340054	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	26.8 ± 2.5 D	2020-01-03
9340059	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	26.5 ± 2.6 D	2020-01-03
9340027	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	26.6 ± 2.5 D	2020-01-03
9341713	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	26.5 ± 2.5 D	2020-01-03
9340081	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	18.4 ± 2.1 D	2020-01-03
9340064	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	26.5 ± 2.5 D	2020-01-03
9340032	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	26.1 ± 2.4 D	2020-01-03
9341718	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	23.7 ± 2.4 D	2020-01-03
9340086	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	26.9 ± 2.6 D	2020-01-03
9340069	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	25.6 ± 2.5 D	2020-01-03
9340037	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	28.4 ± 2.6 D	2020-01-03
9340005	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	???? DIF1	2020-01-03
9340091	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	26.5 ± 2.5 D	2020-01-03
9340096	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	26.2 ± 2.5 D	2020-01-03
9340074	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	27.7 ± 2.5 D	2020-01-03
9340042	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	26.6 ± 2.5 D	2020-01-03
9340010	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	27.5 ± 2.5 D	2020-01-03
9341701	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	22.9 ± 2.3 D	2020-01-03
9340047	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	26.7 ± 2.5 D	2020-01-03
9340015	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	25.4 ± 2.5 D	2020-01-03
9340020	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	24.1 ± 2.4 D	2020-01-03
9341706	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	31.0 ± 2.7 D	2020-01-03

January 3, 2020

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

S

N/A

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9340052	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	27.4 ± 2.6 D	2020-01-03
9340057	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	27.3 ± 2.5 D	2020-01-03
9340025	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	25.1 ± 2.4 D	2020-01-03
9341711	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	22.5 ± 2.2 D	2020-01-03
9340079	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	26.9 ± 2.5 D	2020-01-03
9340062	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	25.6 ± 2.5 D	2020-01-03
9340030	N/A	2019-12-21 @ 8:00 am	2019-12-23 @ 8:00 am	25.0 ± 2.4 D	2020-01-03
9341716	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	25.1 ± 2.4 D	2020-01-03
9340084	N/A	2019-12-21 @ 9:00 am	2019-12-23 @ 9:00 am	24.5 ± 2.3 D	2020-01-03

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

RADON SCREENING SURVEY – FOLLOW-UP BROOKHAVEN ELEMENTARY SCHOOL

4610 Penn Street, Rockville, Maryland 20853

EXECUTIVE SUMMARY

Date of Test Report:	4/6/16 Follow-Up
Round of Testing:	Initial Follow-up Post Remediation
# Rooms Tested	3
# Rooms \geq 4.0 pCi/L:	0
Low Value:	<0.4
High Value:	<0.4
Confirmed Rooms \geq 4.0 pCi/L US EPA Action Level	0

Summary of Sampling Events \geq 4.0 pCi/L

Room	Result (pCi/L) 2/3/16 (Rev 1 Initial)	Result (pCi/L) 4/6/16 Follow-Up	Average Result (pCi/L)
110	<0.3 Tampered	<0.4	<0.4
131A	<0.3 Tampered	Not Accessible	<0.3
Staff Lounge	<0.3 Tampered	<0.4	<0.4
114	Not Accessible	<0.4	<0.4



MCPS RADON TESTING

Executive Summary: Brookhaven Elementary School

Date of Test Report:	4/6/2016
Round of Testing:	Initial Follow-up Post Remediation
# Rooms Tested:	3
# Rooms \geq 4.0 pCi/L:	0
Low Value:	< 0.4
High Value:	<0.4

Project Status:

Retesting completed; no further action at this time.



April 6, 2016

Mr. Richard Cox
Indoor Air Quality Team Leader
Montgomery County Public Schools
850 Hungerford Drive
Rockville, MD 20850

Re: **Radon Testing Services**
KCI Job # 12146341.31

Location: Brookhaven Elementary School
4610 Renn Street
Rockville, MD 20853

Dear Mr. Cox:

KCI Technologies, Inc. (KCI) is pleased to submit the following report to the Montgomery County Public Schools (MCPS) pursuant to completing a “short-term” 3 day radon test for the Brookhaven Elementary School, located at 4610 Renn Street in Rockville, Maryland 20853 (subject site).

Scope of Services:

KCI conducted radon testing at the subject site to evaluate indoor radon levels relative to the USEPA's recommended action level of 4.0 picocuries per Liter (pCi/L) - the level at which EPA recommends that schools take action to reduce the level. KCI conducted the radon testing in accordance with American Association of Radon Scientists and Technologists (AARST) *Protocol for Conducting Measurements of Radon and Radon Decay Products in Schools and Large Buildings*. A National Radon Safety Board (NRSB) Radon Measurement Specialist (certification #14SS056) supervised the testing. Additional information on radon management and the health effects of radon exposure is available from www.montgomerycountymd.gov/dep/air/radon or www.epa.gov/radon.

KCI visited the site on March 21, 2016 and deployed four (4) activated charcoal (AC) radon test kits. KCI deployed radon test kits in frequently-occupied ground contact rooms, and other areas, (if applicable) in accordance with AARST guidance. A floor plan map of the building with the test locations is included as Attachment A of this report.

As a quality control measure, KCI included duplicate samples, field blanks, lab transit blanks, and office blanks in accordance with AARST recommendations. In addition, KCI submitted six (6) test kits to TCS Industries Inc. as spike samples. The spiked tests were exposed to a known radon concentration by TCS prior to being returned to the laboratory for analysis.

KCI returned to the site on March 24, 2016 to retrieve the radon sampling test kits. KCI shipped all radon tests via overnight delivery to AccuStar Labs for analysis by gamma-ray spectroscopy. Accustar Labs is a NRSB certified analytical laboratory for radon analysis (certification # ARL0007) located at 929 Mount

Zion Road, Lebanon, Pennsylvania.

Evaluation of Testing Conditions:

The operating condition that represents the greatest amount of significantly occupied time for this building is; heating active, with outdoor temperature averages $\leq 65^{\circ}$ F.

KCI concludes that the test period reasonably represents normal conditions when the building is significantly occupied. Clear characterization of the radon hazard is most likely to be observed under this normal operating condition. Based on the evaluation of test conditions, this test should reasonably characterize radon hazards.

KCI also conducted observations of field conditions which could affect the results of the test and compiled weather data for the testing period. KCI recorded observations of the following conditions in each room at the time of deployment and collection of the radon test kits:

- Indoor temperature,
- HVAC Operation,
- Dehumidifier operation,
- Humidifier operation,
- Ceiling fan operation, and
- Open windows or doors.

Results:

The results of the radon test analysis indicated the following:

Radon Concentration	Room	Result
≥ 4.0 pCi/L	None	n/a
< 4.0 pCi/L	See Attachment B	

Notes:
D- Duplicate sample

The office blank and lab transit blanks had test results of less than the laboratory detection limit of 0.4 pCi/L. Review of the duplicate sample analysis indicates that adequate laboratory measurement precision was achieved. The Spike sample analysis results indicate the laboratory is operating within statistical control limits.

The sampling locations, field observations, and analytical results are listed on Table 1 (Attachment B). The laboratory analytical results are also attached (Attachment C). Laboratory results and exposure data for the spike samples are also included in Attachment C.

Our professional services have been performed in accordance with customary principles and practices in the field of industrial hygiene and engineering. If you have any questions or comments regarding this report, please feel free to contact me at (410) 316-7800.

Sincerely,



James M. Moulds
Radon Measurement Specialist
KCI Technologies, Inc.

Attachments: A- Floor Plan with Test Locations
 B- Table 1-Radon Test Summary Spreadsheet
 C- Laboratory Analytical Results

ATTACHMENT A

Floor Plan With Test Locations

ATTACHMENT B

Radon Test Summary Spreadsheet

Table Notes:

AC- Activated Charcoal

ACI- Air Chek, Inc.

D- Duplicate

FB- Field Blank

KCI- KCI Technologies, Inc.

OB- Office Blank*

PM- Project Manager

QC- Quality Control

*Office blanks were submitted at a rate of 1% for all samples deployed in Phase 11 testing. Office blanks were not submitted under each school individually.

Radon Testing Results		
Brookhaven Elementary School		
Test Period: 03/21/16-03/24/16		
Kit Number	Room / Area	Result
3029245	110	<0.4
3029262	114	<0.4
3029244	STAFF LOUNGE	<0.4

Table Note:

* Missing or Compromised Sample

Radon Testing Results		
Brookhaven Elementary School		
Test Period: 03/21/16-03/24/16		
Kit Number	QC Type	Result
3029243	D (STAFF LOUNGE)	<0.4

Table Note:

* Missing or Compromised Sample

ATTACHMENT C

Laboratory Analytical Results

NRPP 10511AL
NRSB ARL0007

EPA Method #402-R-92-004
Charcoal Canister
NRPP Device Code 6048
NRSB Device Code 10317

Laboratory Report for:

Property Tested: Project # 12146341

KCI Technologies
936 Ridgebrook Rd
Sparks MD 21152

Brookhaven ES
4610 Renn Street
Rockville MD 20853

Log Number	Device Number	Test Exposure Duration:	Area Tested	Result (pCi/L)
3018403	3029244	03/21/2016 10:35 am 03/24/2016 10:45 am	Staff Lounge First Floor	<0.4
3018404	3029245	03/21/2016 10:40 am 03/24/2016 10:46 am	Bldg 110 First Floor	<0.4
3018405	3029262	03/21/2016 10:45 am 03/24/2016 10:47 am	Bldg 114 First Floor	<0.4
3018406	3029243	03/21/2016 03/24/2016	Staff Lounge First Floor	<0.4

Comment: A copy of this report was emailed to tehsin@kci.com.

Distributed by: KCI Technologies, Inc.

Date Received: 03/28/2016 Date Logged: 03/28/2016 Date Analyzed: 03/28/2016 Date Reported: 03/29/2016

Report Reviewed By: Grace Heubling

Report Approved By: Carolyn D. Koke

Carolyn D. Koke, President, AccuStar Labs

Disclaimer:

The uncertainty of this radon measurement is +/- 10 %. Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.

Radon Device Type Open Face Canister

Send Written Report To:

Name: KCI Technologies, Inc
 Address: 936 Ridgebrook Road
 Address: Sparks
 City/Town: Sparks
 State/Province Postal Code: MD 21152
 Report Country: Baltimore County
 Email Address: tehsin@kci.com

Site Tested:

Site Name: Brookhaven E.S.
 Address: 4616 Revu St.
 Address: Rockville
 City/Town: Rockville
 State/Province Postal Code: MD 20853
 Test Country: Montgomery County
 Project Number: 12146341

Contact Information:

Contact: Tehsin Aurangabadwala
 Telephone: 410-891-1726
 Technician:
 Cert. Number:
 Signature:

Lab Use Only	Device Number	Building Number	Unit Number	Floor	Name of Room	Start Date mm/dd/yyyy	Start Time hh:mm am/pm	Stop Date mm/dd/yyyy	Stop Time hh:mm am/pm	Lab Use Only
	3029244	Stubb Lounge		1		3/21/2016	10:35 AM	3/24/16	10:45 AM	
	3029245	110		6		3/21/2016	10:40 AM	↓	10:46 AM	
	3029262	114		6		3/21/2016	10:45 AM	↓	10:47 AM	
	30292	Stubb Lounge		1		3/21/2016	10:37 AM		10:48 AM	

NRPP 10511AL
NRSB ARL0007

EPA Method #402-R-92-004
Charcoal Canister
NRPP Device Code 6048
NRSB Device Code 10317

Laboratory Report for:

Property Tested: Project # 12146341

KCI Technologies
936 Ridgebrook Rd
Sparks MD 21152

MCPS Radon Phase 11 (re-testing) Office Blank

Log Number	Device Number	Test Exposure Duration:	Area Tested	Result (pCi/L)
3018362	3029232	03/21/2016 8:00 am 03/24/2016 8:00 am	Unit O First Floor Main Room	<0.4

Comment: A copy of this report was emailed to tehsin@kci.com.

Distributed by: KCI Technologies, Inc.

Date Received: 03/28/2016 Date Logged: 03/28/2016 Date Analyzed: 03/28/2016 Date Reported: 03/29/2016

Report Reviewed By: Grace Heubling

Report Approved By: Carolyn D. Koke

Carolyn D. Koke, President, AccuStar Labs

Disclaimer:

The uncertainty of this radon measurement is +/- 10 %. Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.

NRPP 10511AL
NRSB ARL0007

EPA Method #402-R-92-004
Charcoal Canister
NRPP Device Code 6048
NRSB Device Code 10317

Laboratory Report for:

Property Tested:

KCI Technologies
936 Ridgebrook Rd
Sparks MD 21152

MCPS
Transit Blanks

Log Number	Device Number	Test Exposure Duration:		Area Tested	Result (pCi/L)
3010588	3028953	01/19/2016 1:00 pm	01/22/2016 9:30 am	1	< 0.4
3010589	3028955	01/19/2016 1:00 pm	01/22/2016 9:30 am	2	< 0.4
3010590	3028954	01/19/2016 1:00 pm	01/22/2016 9:30 am	3	< 0.4
3010591	3028997	01/19/2016 1:00 pm	01/22/2016 9:30 am	4	< 0.4

Comment: AMENDED REPORT for 3028953-8955, 3028997 on 2/22/16 to add all missing information from the blank datasheet. A copy of this report was emailed to james.mouldsdales@kci.com.

Distributed by: KCI Technologies, Inc.

Date Received: 01/27/2016 Date Logged: 01/27/2016 Date Analyzed: 01/28/2016 Date Reported: 01/28/2016

Report Reviewed By: Christie Bates

Report Approved By: Carolyn D. Koke

Carolyn D. Koke, President, AccuStar Labs

Disclaimer:

The uncertainty of this radon measurement is +/- 10 %. Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.

Return canisters for analysis to:
AccuStar Labs
 929 Mt. Zion Rd., Lebanon, PA 17046
 800-523-4964

AccuStar Labs – Lebanon, PA
INFORMATION FORM - Large Buildings -
 Projects - Apartments

Instructions on back of form
 Read instructions carefully
 Discrepancies will invalidate tests

Test Site Info

Name of Building/Project or Owner: Transit
 Site Address: Transit
 City: _____ State: _____ Zip: _____ County: _____
 Projects Contact Name: Don Coale Phone: _____ Email: _____

Do not use this form in
 New Jersey or Florida
 Call for correct forms.

Multi-Page Report Y-N

LAB USE ONLY	
Wgt. Gain	pCi/L
	LOF
	LOF
	LOF
	LOF

Detector Serial#	ROOM NAME & NUMBER - LOCATION OF DETECTOR IN ROOM (indicate duplicates and blanks)	Floor	Start Date	Start Time Include AM/PM	Stop Date	Stop Time Include AM/PM
3028953	Transit	1	1/19/16	approx: 00pm 1/23/16		9:30am
8955	Transit	1	1/19/16			
8954	Transit	1	1/19/16			
8997	Transit	1	1/19/16			

1/27/2016

KCI Technologies, Inc.

3010588 3028953 ACPC275B EXP12/31/2018

Structure Type: (circle one or more) Basement - Crawlspace - Slab on Grade - Other
Test Purpose: (Circle all that apply) Initial Screening - Follow Up Test - Post Mitigation - Real Estate - Other
Building Type: (Circle One) Residential - Non Residential
 Private Day Care - Private School
 Day Care in Public School - Public School

Both Placed by and Retrieved by signatures are required

Canisters placed by _____ # _____

Canisters retrieved by _____ # _____

Send Results To:

Company Name: KCI Tech
 Address: 936 Ridgebrook
 City: Sparks State: MD Zip: 21152
 Phone: 410-599-3826
 EMAIL Results to: James.Mouldale@kci.com

Were general operating conditions maintained?	Yes - No	explain if NO
Were closed building conditions maintained?	Yes - No	explain if NO
Normal Temp.	Yes - No	
Normal Humidity	Yes - No	
Windy Y-N	Rainy Y-N	

Make sure information is complete and correct.
 If a recalculation is requested there is a \$10.00 recalc fee PER Canister.

Mailing: PO Box 990 Jonestown, PA 17038
 Shipping: 929 Mt Zion Road, Lebanon, PA 17046
 800-523-4964 fax 717-274-5662
 NEHA 10511AL NRSB ARL 0007

TCS INDUSTRIES, INC.

(717) 657-7032

RADON GAS DETECTION

www.radondetek.com

4326 Crestview Road, Harrisburg, PA 17112

James Mouldale
KCI
936 Ridgebrook Rd.
Sparks, MD 21152

April 04, 2016

Dear Mr. Mouldale:

The spike exposure data were:

Start 04/04/16 @ 1110 hrs EDT
End 04/06/16 @ 1113 hrs EDT

AC 3029218, 3029219, 3029220, 3029217, 3029214, 3029217, and 3029166

Average radon concentration was 10.6 pCi/L +/- 5%

Avg. Temp. was 71F
Avg. RH was 51%
Elevation was 490 feet above sea level

Sincerely,



Carl H. Distenfeld, CHP

TCS Radon Chamber NRSB CHM 0002

NRPP 10511AL
NRSB ARL0007

EPA Method #402-R-92-004
Charcoal Canister
NRPP Device Code 6048
NRSB Device Code 10317

Laboratory Report for:

Property Tested:

KCI Technologies
936 Ridgebrook Rd
Sparks MD 21152

MCPS
Radon Spike Sample Laboratory Results


Log Number	Device Number	Test Exposure Duration:	Area Tested	Result (pCi/L)
3020102	3029166	04/04/2016 11:10 am 04/06/2016 11:13 am	Not Indicated	11.9
3020103	3029214	04/04/2016 11:10 am 04/06/2016 11:13 am	Not Indicated	11.5
3020104	3029217	04/04/2016 11:10 am 04/06/2016 11:13 am	Not Indicated	10.7
3020105	3029218	04/04/2016 11:10 am 04/06/2016 11:13 am	Not Indicated	11.3
3020106	3029219	04/04/2016 11:10 am 04/06/2016 11:13 am	Not Indicated	11.0
3020107	3029220	04/04/2016 11:10 am 04/06/2016 11:13 am	Not Indicated	10.5

Comment: A copy of this report was emailed to james.mouldsdale@kci.com.

Distributed by: KCI Technologies, Inc.

Date Received: 04/07/2016 Date Logged: 04/07/2016 Date Analyzed: 04/07/2016 Date Reported: 04/08/2016

Note: Spike samples are test canisters that are deliberately exposed to a controlled high level of radon in a laboratory. They provide a quality control measure in the testing process and do NOT reflect radon levels in the building being tested.

Report Reviewed By: 

Report Approved By: 
Carolyn D. Koke, President, AccuStar Labs

Disclaimer:

The uncertainty of this radon measurement is +/- 10 %. Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.


Send Written Report To:

Name: KCI Technologies, Inc
 Address: 936 Ridgebrook Road
 Address:
 City / Town: Sparks
 State/Province Postal Code: MD 21152
 Report Country: Baltimore County
 Email Address: tehsin@kci.com

Site Tested:

Site Name: MCRS
 Address: 850 Hagerford Dr
 Address:
 City / Town: Rockville
 State/Province Postal Code: MD 20850
 Test Country: Montgomery County
 Project Number: 12146341

Contact Information:

Contact: Tehsin Aurangabadwala
 Telephone: 410-891-1726
 Technician:
 Cert. Number:
 Signature: 

Lab Use Only	Device Number	Building Number	Unit Number	Floor	Name of Room	Temp	Start Date mm/dd/yyyy	Start Time hh:mm am / pm	Stop Date mm/dd/yyyy	Stop Time hh:mm am / pm	Lab Use Only
	3029166	1		1	1		4/4/16	11:10am	4/6/16	11:15am	
	3029214	1		1	2						
	3029217	1		1	3						
	3029218	1		1	4						
	3029219	1		1	5						
	3029220	1		1	6						



MCPS RADON TESTING

Executive Summary: Brookhaven Elementary School

Date of Test Report:	2/03/2016 (Rev.1)
Round of Testing:	Initial Follow-up Post Remediation
# Rooms Tested:	41
# Rooms \geq 4.0 pCi/L:	0
Low Value:	< 0.3
High Value:	1.2

Project Status:

Initial testing completed; compromised samples need re-test.



February 3, 2016 (Rev.1)

Mr. Richard Cox
Indoor Air Quality Team Leader
Montgomery County Public Schools
850 Hungerford Drive
Rockville, MD 20850

Re: **Radon Testing Services**
KCI Job # 12146341.24

Location: Brookhaven Elementary School
4610 Renn Street
Rockville, MD 20853

Dear Mr. Cox:

KCI Technologies, Inc. (KCI) is pleased to submit the following report to the Montgomery County Public Schools (MCPS) pursuant to completing a “short-term” 3 day radon test for the Brookhaven Elementary School, located at 4610 Renn Street in Rockville, Maryland 20853 (subject site).

Scope of Services:

KCI conducted radon testing at the subject site to evaluate indoor radon levels relative to the USEPA's recommended action level of 4.0 picocuries per Liter (pCi/L) - the level at which EPA recommends that schools take action to reduce the level. KCI conducted the radon testing in accordance with American Association of Radon Scientists and Technologists (AARST) *Protocol for Conducting Measurements of Radon and Radon Decay Products in Schools and Large Buildings*. A National Radon Safety Board (NRSB) Radon Measurement Specialist (certification #14SS056) supervised the testing. Additional information on radon management and the health effects of radon exposure is available from www.montgomerycountymd.gov/dep/air/radon or www.epa.gov/radon.

KCI visited the site on January 11, 2016 and deployed fifty-one (51) activated charcoal (AC) radon test kits. KCI deployed radon test kits in frequently-occupied ground contact rooms, and other areas, (if applicable) in accordance with AARST guidance. A floor plan map of the building with the test locations is included as Attachment A of this report.

As a quality control measure, KCI included duplicate samples, field blanks, lab transit blanks, and office blanks in accordance with AARST recommendations. In addition, KCI submitted six (6) test kits to Bowser-Morner, Inc. as spike samples. The spiked tests were exposed to a known radon concentration by Bowser-Morner prior to being returned to the laboratory for analysis.

KCI returned to the site on January 14, 2016 to retrieve the radon sampling test kits. KCI shipped all radon tests via overnight delivery to Airchek, Inc. for analysis by gamma-ray spectroscopy. Airchek, Inc. is a NRSB certified analytical laboratory for radon analysis (certification # ARL1402) located at 1936

Butler Bridge Road, Mills River, North Carolina.

Evaluation of Testing Conditions:

The operating condition that represents the greatest amount of significantly occupied time for this building is; heating active, with outdoor temperature averages $\leq 65^{\circ}$ F.

KCI concludes that the test period reasonably represents normal conditions when the building is significantly occupied. Clear characterization of the radon hazard is most likely to be observed under this normal operating condition. Based on the evaluation of test conditions, this test should reasonably characterize radon hazards.

KCI also conducted observations of field conditions which could affect the results of the test and compiled weather data for the testing period. KCI recorded observations of the following conditions in each room at the time of deployment and collection of the radon test kits:

- Indoor temperature,
- HVAC Operation,
- Dehumidifier operation,
- Humidifier operation,
- Ceiling fan operation, and
- Open windows or doors.

Results:

The results of the radon test analysis indicated the following:

Radon Concentration	Room	Result
≥ 4.0 pCi/L	none	n/a
< 4.0 pCi/L	See Attachment B	

Notes:
D- Duplicate sample

All field blanks, office blank, and lab transit blanks had test results of less than the laboratory detection limit of 0.3 pCi/L. Review of the duplicate sample analysis indicates that adequate laboratory measurement precision was achieved. The Spike sample analysis results indicate the laboratory is operating within statistical control limits.

The sampling locations, field observations, and analytical results are listed on Table 1 (Attachment B). The laboratory analytical results are also attached (Attachment C). Laboratory results and exposure data for the spike samples are also included in Attachment C.

Our professional services have been performed in accordance with customary principles and practices in the field of industrial hygiene and engineering. If you have any questions or comments regarding this report, please feel free to contact me at (410) 316-7800.

Sincerely,



H. Allen Bennett
Certified Industrial Hygienist
KCI Technologies, Inc.

Attachments: A- Floor Plan with Test Locations
 B- Table 1-Radon Test Summary Spreadsheet
 C- Laboratory Analytical Results

ATTACHMENT A

Floor Plan With Test Locations

ATTACHMENT B

Radon Test Summary Spreadsheet

Table Notes:

AC- Activated Charcoal

ACI- Air Chek, Inc.

D- Duplicate

FB- Field Blank

KCI- KCI Technologies, Inc.

OB- Office Blank

PM- Project Manager

QC- Quality Control

Radon Testing Results		
Brookhaven Elementary School		
Test Period: 01/11/16-01/14/16		
Kit Number	Room / Area	Result
7717138	101	< 0.3
7717137	103	0.7
7717136	105	0.9
7717135	108	< 0.3
7717134	109	< 0.3
7717132	111	< 0.3
7717131	112	< 0.3
7717130	113	< 0.3
7717141	118	0.7
7717140	127	< 0.3
7717128	130	< 0.3
7717129	131	0.9
7717127	132	< 0.3
7717126	133	0.8
7717125	134	< 0.3
7717124	135	1.2
7717118	136	1.1
7717121	137	0.6
7717117	138	1.1
7717119	139	< 0.3
7717111	161	< 0.3
7717123	162	< 0.3
7717112	163	< 0.3
7717116	164	< 0.3
7717115	164	0.6
7717113	166	< 0.3
7717147	222	0.9
7717149	224	0.6
7717150	226	< 0.3
7717133	* 110 (Tampered)	< 0.3
7717142	* 131 A (Tampered)	< 0.3
7717122	137A	0.7
7717146	AP ROOM	< 0.3
7717145	AP ROOM	< 0.3
7717107	ASST PRINC	< 0.3
7717110	CONF	< 0.3
7717101	GEN OFFICE	< 0.3
7717106	HEALTH ROOM	< 0.3
7717105	MAIL ROOM	< 0.3
7717143	MC OFFICE	< 0.3
7717144	MEDIA CENTER	< 0.3
7717104	PRIN OFFICE	< 0.3
7717139	* STAFF LOUNGE (Tampered)	< 0.3

Table Note:

* Missing or Compromised Sample

Radon Testing Results		
Brookhaven Elementary School		
Test Period: 01/11/16-01/14/16		
Kit Number	QC Type	Result
7717120	D (139)	0.6
7717114	D (166)	< 0.3
7717148	D (222)	< 0.3
7717108	D (ASST PRINC)	< 0.3
7717102	D (GEN OFFICE)	< 0.3
7717109	FB (ASST PRINC)	< 0.3
7717103	FB (GEN OFFICE)	< 0.3
7716769	OB (0)	< 0.3

Table Note:

* Missing or Compromised Sample

ATTACHMENT C

Laboratory Analytical Results

February 1, 2016
LABORATORY ANALYSIS REPORT **

Radon test result report for:
BROOKHAVEN ELEMENTARY SCHOOL MAIN

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7716769	0	2016-01-11 @ 5:00 pm	2016-01-14 @ 1:00 pm	< 0.3	2016-01-19
7717138	101	2016-01-11 @ 11:00 am	2016-01-14 @ 10:00 am	< 0.3	2016-01-19
7717137	103	2016-01-11 @ 11:00 am	2016-01-14 @ 10:00 am	0.7 ± 0.3	2016-01-19
7717136	105	2016-01-11 @ 11:00 am	2016-01-14 @ 10:00 am	0.9 ± 0.3	2016-01-19
7717135	108	2016-01-11 @ 11:00 am	2016-01-14 @ 10:00 am	< 0.3	2016-01-19
7717134	109	2016-01-11 @ 11:00 am	2016-01-14 @ 10:00 am	< 0.3	2016-01-19
7717133	110	2016-01-11 @ 11:00 am	2016-01-14 @ 10:00 am	< 0.3	2016-01-19
7717132	111	2016-01-11 @ 11:00 am	2016-01-14 @ 10:00 am	< 0.3	2016-01-19
7717131	112	2016-01-11 @ 11:00 am	2016-01-14 @ 10:00 am	< 0.3	2016-01-19
7717130	113	2016-01-11 @ 11:00 am	2016-01-14 @ 10:00 am	< 0.3	2016-01-19
7717141	118	2016-01-11 @ 11:00 am	2016-01-14 @ 10:00 am	0.7 ± 0.4	2016-01-19
7717140	127	2016-01-11 @ 11:00 am	2016-01-14 @ 10:00 am	< 0.3	2016-01-19
7717128	130	2016-01-11 @ 11:00 am	2016-01-14 @ 10:00 am	< 0.3	2016-01-19
7717142	131A	2016-01-11 @ 12:00 pm	2016-01-14 @ 10:00 am	< 0.3	2016-01-19
7717129	131	2016-01-11 @ 11:00 am	2016-01-14 @ 10:00 am	0.9 ± 0.4	2016-01-19
7717127	132	2016-01-11 @ 11:00 am	2016-01-14 @ 10:00 am	< 0.3	2016-01-19
7717126	133	2016-01-11 @ 11:00 am	2016-01-14 @ 9:00 am	0.8 ± 0.4	2016-01-19
7717125	134	2016-01-11 @ 11:00 am	2016-01-14 @ 9:00 am	< 0.3	2016-01-19
7717124	135	2016-01-11 @ 11:00 am	2016-01-14 @ 9:00 am	1.2 ± 0.4	2016-01-19
7717118	136	2016-01-11 @ 11:00 am	2016-01-14 @ 9:00 am	1.1 ± 0.4	2016-01-19
7717121	137	2016-01-11 @ 11:00 am	2016-01-14 @ 9:00 am	0.6 ± 0.3	2016-01-19
7717122	137A	2016-01-11 @ 11:00 am	2016-01-14 @ 9:00 am	0.7 ± 0.4	2016-01-19
7717117	138	2016-01-11 @ 11:00 am	2016-01-14 @ 9:00 am	1.1 ± 0.4	2016-01-19
7717119	139	2016-01-11 @ 11:00 am	2016-01-14 @ 9:00 am	< 0.3	2016-01-19
7717120	139	2016-01-11 @ 11:00 am	2016-01-14 @ 9:00 am	0.6 ± 0.4	2016-01-19
7717111	161	2016-01-11 @ 11:00 am	2016-01-14 @ 9:00 am	< 0.3	2016-01-19
7717123	162	2016-01-11 @ 11:00 am	2016-01-14 @ 9:00 am	< 0.3	2016-01-19
7717112	163	2016-01-11 @ 11:00 am	2016-01-14 @ 9:00 am	< 0.3	2016-01-19
7717115	164	2016-01-11 @ 11:00 am	2016-01-14 @ 9:00 am	0.6 ± 0.4	2016-01-19
7717116	164	2016-01-11 @ 11:00 am	2016-01-14 @ 9:00 am	< 0.3	2016-01-19
7717113	166	2016-01-11 @ 11:00 am	2016-01-14 @ 9:00 am	< 0.3	2016-01-19
7717114	166	2016-01-11 @ 11:00 am	2016-01-14 @ 9:00 am	< 0.3	2016-01-19
7717147	222	2016-01-11 @ 12:00 pm	2016-01-14 @ 10:00 am	0.9 ± 0.4	2016-01-19
7717148	222	2016-01-11 @ 12:00 pm	2016-01-14 @ 10:00 am	< 0.3	2016-01-19
7717149	224	2016-01-11 @ 12:00 pm	2016-01-14 @ 10:00 am	0.6 ± 0.4	2016-01-19
7717150	226	2016-01-11 @ 12:00 pm	2016-01-14 @ 10:00 am	< 0.3	2016-01-19
7717145	AP ROOM	2016-01-11 @ 12:00 pm	2016-01-14 @ 10:00 am	< 0.3	2016-01-19

February 1, 2016
**LABORATORY ANALYSIS
REPORT ****

Radon test result report for:
**BROOKHAVEN ELEMENTARY SCHOOL
MAIN**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7717146	AP ROOM	2016-01-11 @ 12:00 pm	2016-01-14 @ 10:00 am	< 0.3	2016-01-19
7717107	ASST PRINC	2016-01-11 @ 11:00 am	2016-01-14 @ 9:00 am	< 0.3	2016-01-19
7717108	ASST PRINC	2016-01-11 @ 11:00 am	2016-01-14 @ 9:00 am	< 0.3	2016-01-19
7717109	ASST PRINC	2016-01-11 @ 11:00 am	2016-01-14 @ 9:00 am	< 0.3	2016-01-19
7717110	CONF	2016-01-11 @ 11:00 am	2016-01-14 @ 9:00 am	< 0.3	2016-01-19
7717101	GEN OFFICE	2016-01-11 @ 11:00 am	2016-01-14 @ 9:00 am	< 0.3	2016-01-19
7717102	GEN OFFICE	2016-01-11 @ 11:00 am	2016-01-14 @ 9:00 am	< 0.3	2016-01-19
7717103	GEN OFFICE	2016-01-11 @ 11:00 am	2016-01-14 @ 9:00 am	< 0.3	2016-01-19
7717106	HEALTH ROOM	2016-01-11 @ 11:00 am	2016-01-14 @ 9:00 am	< 0.3	2016-01-19
7717105	MAIL ROOM	2016-01-11 @ 11:00 am	2016-01-14 @ 9:00 am	< 0.3	2016-01-19
7717143	MC OFFICE	2016-01-11 @ 12:00 pm	2016-01-14 @ 10:00 am	< 0.3	2016-01-19
7717144	MEDIA CENTER	2016-01-11 @ 12:00 pm	2016-01-14 @ 10:00 am	< 0.3	2016-01-19
7717104	PRIN OFFICE	2016-01-11 @ 11:00 am	2016-01-14 @ 9:00 am	< 0.3	2016-01-19
7717139	STAFF LOUNGE	2016-01-11 @ 11:00 am	2016-01-14 @ 10:00 am	< 0.3	2016-01-19

February 2, 2016
LABORATORY ANALYSIS REPORT

Radon test result report for:
MCPS PHASE 5 & 6 TRANSIT BLANKS

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7722194	1	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7718494	10	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7718475	11	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7718495	12	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7718496	13	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7718497	14	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7718498	15	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7718499	16	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7718500	17	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7718296	18	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7718295	19	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7722195	2	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7716789	20	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7716785	21	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-26
7716791	22	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7716786	23	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7716793	24	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7718274	25	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7716792	26	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7718294	27	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7718293	28	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7718292	29	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7722197	3	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7718290	30	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7722198	4	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7722199	5	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7722211	6	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7718491	7	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27
7718476	8	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-26
7718479	9	2016-01-19 @ 12:00 pm	2016-01-22 @ 12:00 pm	< 0.3	2016-01-27

December
23,
2015

**LABORATORY ANALYSIS
REPORT ****

Spike Sample Laboratory Results

Radon test result report for:
MCPS

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7706380	101	2015-12-18 @ 9:00 am	2015-12-21 @ 9:00 am	25.2	2015-12-23
7706381	102	2015-12-18 @ 9:00 am	2015-12-21 @ 9:00 am	26.5	2015-12-23
7706208	103	2015-12-18 @ 9:00 am	2015-12-21 @ 9:00 am	27.7	2015-12-23
7705132	104	2015-12-18 @ 9:00 am	2015-12-21 @ 9:00 am	28.6	2015-12-23
7706366	105	2015-12-18 @ 9:00 am	2015-12-21 @ 9:00 am	26.5	2015-12-23
7706211	106	2015-12-18 @ 9:00 am	2015-12-21 @ 9:00 am	26.1	2015-12-23

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

Note: Spike samples are test canisters that are deliberately exposed to a controlled high level of radon in a laboratory. They provide a quality control measure in the testing process and do NOT reflect radon levels in the building being tested.

EXPOSURE IN BOWSER-MORNER RADON CHAMBER

CLIENT KCI Technologies Inc. Job Number 173224

NOMINAL Conditions: Radon Conc 26.9 pCi/L Rel. Hum 49.6 % Temp. 69.9 F

Date Start: 12/18/15 Date Stop: 12/21/15 Date Start: _____ Date Stop: _____

Time Start: 0929 Time Stop: 0929 Time Start: _____ Time Stop: _____

Device No.'s: 7705132, 7706208, Device No.'s: _____

7706211, 7706366, _____

7706380, 7706381 _____

F3 Left

Date Start: _____ Date Stop: _____ Date Start: _____ Date Stop: _____

Time Start: _____ Time Stop: _____ Time Start: _____ Time Stop: _____

Device No.'s: _____ Device No.'s: _____

Date Start: _____ Date Stop: _____ Date Start: _____ Date Stop: _____

Time Start: _____ Time Stop: _____ Time Start: _____ Time Stop: _____

Device No.'s: _____ Device No.'s: _____

Note: All times are in 24-hour (military) notation, Eastern Standard Time (EST)
Background = 7 μ R/h Elevation = 820 ft



Chain of Custody

Project Name: MCPS Radon Phase V

Name of Schools:

- | | | |
|-------------------------|---------------------------|-------------------------|
| 1. Arcola ES | 11. Clopper Mill ES | 21. Parkland Magnet MS |
| 2. Argyle ES | 12. College Gardens ES | 22. Rachel Carson ES |
| 3. Bells Mill ES | 13. Eastern MS | 23. Roberto Clemente MS |
| 4. Bethesda ES | 14. Fallsmead ES | 24. Rock Creek ES |
| 5. Brookhaven ES | 15. Fields Road ES | 25. Rockview ES |
| 6. Burning Tree ES | 16. Flower Hill ES | 26. Rockville HS |
| 7. Capt. James Daly ES | 17. Flower Valley ES | 27. Rocky Hill MS |
| 8. Carderock Springs ES | 18. Fox Chapel ES | 28. Seneca Valley HS |
| 9. Cashell ES | 19. Glen Haven ES | 29. Westover ES |
| 10. Clearspring ES | 20. James Hubert Blake HS | 30. William Farquar MS |

	Date	Initials
Radon Test Kits Deployed	1/11/16	JM
Radon Test Kits Sampled	1/14/16	JM
Radon Test Kits Shipped to Lab*	1/15/16	JM
Radon Test Kits Received by Lab*	1/18/16	JM

*All samples sent to Air Check, Inc., 1936 Butler Bridge Road, Mills River, NC 28758